



NOTE:

1. FOR SERVICE LINE 8" OR GREATER, SAMPLE TEE MUST BE 2" LARGER THAN SERVICE PIPE SIZE.

SAMPLE PORT

The City of San Marcos
DEPARTMENT OF ENVIRONMENT & ENGINEERING

STANDARD DETAIL

N.T.S.

APPROVED BY:

SABAS AVILA, P.E., INTERIM DIRECTOR

DATE

DRAWING: T/DETAILS/WW-SAMPLEPORT 04-08.DGN