



**FINANCE DEPARTMENT – PURCHASING AND CONTRACTING DIVISION**

**ADDENDUM # 223-115 Road Building Materials**

June 20, 2023

This addendum will be considered a part of the Road Building Materials 223-115. Where provisions of this addendum differ from those of the original Contract Documents, this addendum will govern.

Q. After reviewing the solicitation and the City's website and its material specifications, I cannot determine the PG Binder required for the Hot Mix (Black Base Type B, Type C HMAC or Type D HMAC)

A. See PG 64-22

Q. I saw the notes that up to 20% RAP will be allowed in all mixes except the final riding surface. Will that be the Type C or Type D product or both?

A. Mainly D, but possibly both

Sincerely,

Dustan Lukasik, CTCD  
Purchasing Specialist Senior